


NOTES:

- 1) POST SHALL BE PAINTED WHITE AND SHALL BE SET IN CONCRETE. AFFIX ADHESIVE "HIGH PRESSURE WATERLINE" STICKER AS SHOWN ABOVE.
- 2) THE ENTIRE SIGN SHALL BE FURNISHED BY THE NORTH MARIN WATER DISTRICT.
- 3) THIS SIGN SHALL BE INSTALLED IN OPEN SPACE LOCATIONS, OR IN EASEMENTS, TO ASSIST IN THE LOCATING OF WATER MAINS AND TO SERVE AS A WARNING TO ANYONE EXCAVATING IN THIS AREA.
- 4) REFER TO NMWD TECHNICAL SPECIFICATION 03000 FOR CONCRETE REQUIREMENTS.
- 5) WELD ON OR STAMP OFFSET PIPE DISTANCE "d" AND ARROW POINTING TO THE DIRECTION OF PIPE.
- 6) THE FIRST SIGN SHALL BE VISIBLE FROM THE STREET AND ALL CONSECUTIVE SIGNS MUST BE VISIBLE FROM THE PRIOR SIGN.

 NORTH MARIN WATER DISTRICT			
SIGN FOR HIGH PRESSURE WATERLINE			
APPROVED	DATE	REV	STD NO
<i>R. [Signature]</i>	09/05/19	2	20