



NOTES:

- 1) FOR WATER SERVICE INSTALLATION REFER TO NMWD STD. NO.15
- 2) ALL MATERIAL TO BE BRASS OR COPPER
- 3) USE INSULATING COUPLINGS IF CONNECTING TO GALV. STEEL OR OTHER FERROUS METALS.

PARTS LIST:

1	1/4 TURN FULL PORT BALL VALVE (BRASS)
2	THREADED NIPPLE, (BRASS)
3	UNION, FEMALE (BRASS)
4	PRESSURE REDUCING VALVE DOUBLE UNION, ZURN WILKINS 600XL OR APPROVED EQUAL



TYPICAL PRESSURE REGULATING VALVE (PRIVATE RESIDENCE)

APPROVED	DATE	REV	STD NO
<i>[Signature]</i>	09/05/19	2	28