



**NOTES:**

- 1) FOR VALVE RISER REFER TO NMWD STD.2, SIMILAR
- 2) ALONG STREETS WITH NO CURB OR SIDEWALK METER BOX SHALL BE INSTALLED AS FAR AS POSSIBLE AWAY FROM EDGE OF PAVEMENT AS DIRECTED BY THE DISTRICT.
- 3) FOR CONCRETE THRUST BLOCKING REFER TO NMWD STD.3
- 4) BEFORE BACKFILLING, PRIME AND COAL TAR WRAP FLANGES, BOLT RINGS AND EXPOSED STEEL PIPE.
- 5) IF LOCATED IN TRAVEL WAY, PROVIDE TRAFFIC-RATED LID AND BOX.

**PARTS LIST**

1	6" GATE VALVE POxF OR 6" GATE VALVE FF (FOR STEEL MAIN)
2	6" 90° ELBOW FF
3	6" STEEL PIPE, CEMENT MORTAR LINED
4	6" SLIP-ON WELD FLANGE
5	6" BLIND FLANGE THREADED 4"
6	4" BRASS MALE THREAD PLUG. HAND-TIGHT W/ANTI-SEIZE COMPOUND
7	6" GASKET
8	3/4"x3-1/2" 316 S.S. BOLTS & NUTS
9	3" METER BOX WITH LID, CHRISTY B40 OR EQUAL



**6" BLOW-OFF ASSEMBLY  
(FOR 12" MAINS AND LARGER)**

APPROVED	DATE	REV	STD NO
<i>[Signature]</i>	09/05/19	3	7