

NORTH MARIN WATER DISTRICT
REGULATION 21
FACILITY SIZE AND DESIGN

All extensions of the District's water distribution system shall be designed by the District and constructed in accordance with the District's plans and specifications. The location, size, type and design of all such extensions shall be sufficient to provide adequate water service for the entire area that can economically be supplied therefrom as conclusively determined by the District. The diameter of pipeline extensions shall not be less than six inches. The diameter of service lines shall not be less than one inch.