



NOTES:

- 1) BEFORE BACKFILLING, PRIME AND COAL TAR WRAP EXPOSED STEEL PIPE AND TRANSITION COUPLING
- 2) FOR TRENCH SECTION REFER TO NMWD. STD. NO.1
- 3) USE ONLY WHERE:

MAIN	:	≤ 12" DIA.
PRESSURE	:	≤ 80 PSI
Δ	:	≤ 3'-0"

 LOCATION IS NOT NEAR A PUMP STATION
- 4) ALL STEEL PIPE AND ELBOWS TO BE CEMENT MORTAR OR EPOXY LINED.
- 5) PRESSURE TEST STEEL PIPE LOWERING PRIOR TO PLACING INTO SERVICE
- 6) STEEL LOWERING TO INCLUDE ANODE PER NMWD STD. NO.12
- 7) FOR CONCRETE ANCHOR BLOCKS FOR VERTICAL BENDS REFER TO NMWD STD. NO.4

Jun 23, 2020 - 11:05am C:\JOB\MISC\STD\WEBSITE\10.dwg User: SUSAN

NORTH MARIN WATER DISTRICT			
TYPICAL STEEL WATERMAIN LOWERING			
APPROVED	DATE	REV	STD NO
	5/16/02	1	10