



NOTES:

- 1) FOR APPROVED BEDDING AND BACKFILL MATERIAL AND COMPACTION REQUIREMENTS SEE NMWD SPECIFICATION 02223. UNLESS OTHERWISE APPROVED BY NMWD, BEDDING AND BACKFILL MATERIAL ARE THE SAME, COMMONLY KNOWN AS PEA AND SAND.
- 2) 1'-8" MIN. COVER DURING CONSTRUCTION.
- 3) PROVIDE A 3" THICK LIFT OF CLASS II AGGREGATE BASE WHERE THE TRENCH WILL BE OPEN FOR EXTENDED PERIODS OF TIME AND THE TRENCH BACKFILL MAY DETERIORATE DUE TO CONSTRUCTION TRAFFIC.
- 4) TRENCH RESTORATION AT EXISTING PAVEMENT TO BE IN ACCORDANCE WITH NMWD SPECIFICATION 02700, AND REQUIRED APPLICABLE CITY/COUNTY STANDARDS.
- 5) WHERE INDICATED ON THE PLAN, INSTALL 2" PVC SCH.40 CONDUIT FOR TELEMETERING CABLE.
- 6) # 10 AWG TW-SOLID LOCATING WIRE TAPED AT 10 FOOT INTERVALS ON NON METALLIC PIPE
- 7) 6-INCH WIDE WARNING/IDENTIFICATION TAPE. BLUE(POTABLE WATER), PURPLE(RECYCLED WATER)
- 8) AS REQUIRED BY NMWD. SEE CONSTRUCTION PLANS.

GENERAL NOTES:

- 9) NO PIPELINES, VALVES OR STRUCTURES SHALL BE BACKFILLED WITHOUT DISTRICT APPROVAL.
- 10) FOR MINIMUM POTABLE WATER, RECYCLED WATER AND SEWER LINE SEPARATION REQUIREMENTS SEE STD. DRAWING NO.S 29, 30 AND 31. FOR ALL OTHER UTILITIES (E.G. STORM DRAIN, PRIVATE MAINS, GAS, ETC) MAINTAIN MINIMUM 5'-0" HORIZONTAL AND 1'-0" VERTICAL SEPARATION IN SEPARATE TRENCHES.



TRENCH SECTION

APPROVED	DATE	REV	STD NO
	8/3/12	5	1