

CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 1: NEW RECYCLED WATER OR SEWER MAINS
ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL SEWER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B PVC SEWER PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR SEWER MAINS. C-900, DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 20' CONTINUOUS SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED OR SEWER PIPE INSTALLED IN A CASING (FOR SEWER MAINS)
A 20' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 8' CONTINUOUS SECTION OF PVC SEWER PIPE CENTERED AT THE MAIN BEING CROSSED, OR SEWER PIPE INSTALLED IN A CASING FOR (SEWER MAINS)
A 8' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (E)
(2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22

CONSTRUCTION REQUIREMENTS FOR WATER, RECYCLED WATER AND SEWER MAINS

CASE 2: NEW WATER OR RECYCLED WATER MAINS
ZONE

- A SPECIAL PERMISSION REQUIRED. DO NOT LOCATE ANY PARALLEL WATER OR RECYCLED WATER MAINS IN THIS AREA WITHOUT DISTRICT AND STATE HEALTH DEPARTMENT APPROVAL
- B C-900 DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR WATER MAINS
C-900, DR14 OR C-905, DR18 PVC PIPE WITH PUSH-ON TYPE RUBBER RING JOINTS FOR RECYCLED WATER MAINS
- C A 20' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS)
A 20' SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- D A 16' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR WATER PIPE INSTALLED IN A CASING (FOR WATER MAINS)
A 16' CONTINUOUS SECTION OF C-900, DR14 OR C-905, DR18 PVC RECYCLED WATER PIPE CENTERED AT THE MAIN BEING CROSSED, OR RECYCLED WATER PIPE INSTALLED IN A CASING (FOR RECYCLED WATER MAINS)
- P PROHIBITED ZONE; NO SEWER, WATER OR RECYCLED WATER MAINS; SECTION 64630 (E)
(2) CALIFORNIA ADMINISTRATIVE CODE, TITLE 22



WATER, RECYCLED WATER AND SEWER
MAIN PARALLEL AND PERPENDICULAR
SEPARATION NOTES

APPROVED	DATE	REV	STD NO
	12/28/10	0	31