


NOTES:

1. FOR VALVE RISER REFER TO NMWD STD.2
2. FOR CONCRETE THRUST BLOCKING REFER TO NMWD STD.3
3. BEFORE BACKFILLING, WRAP FLANGES AND BOLT RINGS WITH 10 MIL TAPE.
4. PRIME AND COAL TAR WRAP EXPOSED STEEL PIPE.
5. ALONG STREETS WITH NO CURB OR SIDEWALK FIRE HYDRANT SHALL BE INSTALLED 2'-6" AWAY FROM EDGE OF PAVEMENT. FOR FIRE HYDRANT MATERIALS REFER TO NMWD SPECIFICATION P-3.
6. INSTALL FIRE HYDRANT SO THAT LARGEST OUTLET FACES STREET.


PARTS LIST:

1	6" FIRE HYDRANT
2	6"x6"LONG HYDRANT EXTENSION WITH BREAKAWAY RING (AS REQ'D)
3	6"x6"x36"LONG BURY POxF
4	6"x6"x36"LONG BURY FF
5	6" GASKET
6	5/8"x3" 316 S.S. BOLTS & NUTS



NORTH MARIN WATER DISTRICT

TYPICAL FIRE HYDRANT INSTALLATION

APPROVED 	DATE 7\19\02	REV 1	STD NO 5
---	-----------------	----------	-------------

THIS STANDARD REPLACES NMWD STD-A-10, STD-A-11, STD-A-30