

NORTH MARIN WATER DISTRICT

REGULATION 21

FACILITY SIZE AND DESIGN

All extensions or modifications of the District's water distribution system shall be designed in accordance with District Standards. The design of extensions or modifications of the water distribution system shall be performed either by the District or by the Applicant's licensed engineer. The District shall have final review and approval authority over designs performed by the Applicant's engineer. All extensions or modifications shall be constructed in accordance with the plans and specifications approved by the District. The location, size, type, and design of all such extensions or modifications shall be sufficient to provide adequate water service for the entire area that can economically be supplied therefrom as conclusively determined by the District. The diameter of pipeline extensions shall not be less than six inches unless determined by the District that a smaller pipeline diameter is acceptable. The diameter of service lines shall not be less than one inch.